


SECTIONAL PLAN

NOTE: PROVIDE MINIMUM OF 3' COVER FOR SERVICE LINE.



SECTION A-A

NOTE: THIS DETAIL FOR USE ON 4" SERVICE LINES CONNECTED TO EXIST. MANHOLES, AND ON A CASE BY CASE BASIS AS APPROVED BY THE ENGINEER.

NOTE: MANHOLE STEPS TO BE VERTICALLY IN LINE WITH "INVERT OUT" FOR PIPE 18" AND LESS. OVER 18" TO BE LOCATED IN LINE WITH BENCH.

FOR DROPS LESS THAN 3'-0" ADJUST SERVICE DEPTH TO MATCH MANHOLE BENCH ELEVATION.

STANDARD DETAIL	
CITY OF CAYCE	
DROP SERVICE CONNECTION	
APPROVED:	# CAYCE-5